

156891

Monsanto

FROM
(NAME-LOCATION-PHONE) T. Carrico, Ext. 2095

DATE	March 4, 1985	cc: L. Bumbicka
SUBJECT	Status Report on CEA 3808	K. Lichtenheld - CS6G
REFERENCE		R. Nelson
		K. Petterson
		O. Shipley
		B. Steketee
TO	P. Hoemann	

Sewer box LDD was stripped of forms.

The joint east of LCC that impacts on getting track 8C back in service was repaired a second time, retest this week.

Excavation for lateral 34 and 35 was done. Smaller pipe will arrive this week.

Plant changed out #4 dewatering pump Friday. The pump installed on February 21 went to ground shortly after it was installed.

Poured 85 cubic yards of concrete encasement from LBB to 14 foot east of LCC. This excluded the one leaking joint which was isolated.


Tom Carrico
Operation Foreman

skg

WCK 4084771

IN-1120